




Product Service

CERTIFICATE

No. Z2 118476 0007 Rev. 00

Holder of Certificate: **VESPA ENERJI SANAYI TICARET AS**
KARPUZSEKISI MAH. 34 CAD.
SAFRANO MOBILYA NO: 30
HACILAR
38210 KAYSERI
TÜRKIYE

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062260302-00

Valid until: 2028-04-26

Date, 2023-12-29

(Zhulin Zhang)



CERTIFICATE

No. Z2 118476 0007 Rev. 00

Model(s): 182 cell modules
 VSPxxxT-M10-144H (xxx=530 to 555 in step of 5)
 VSPxxxT-M10-120H (xxx=440 to 460 in step of 5)
 xxx stands for rated output power at STC

Parameters:

Construction:	Framed with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790
PID test condition:	±1500 V, 96 Hours, 85 °C, 85 % RH

Remark:PID testing method is according to IEC TS 62804-1:2015

Tested according to: IEC 61215-1:2016
 IEC 61215-1-1:2016
 IEC 61215-2:2016
 IEC 61730-1:2016
 IEC 61730-2:2016
 PPP 58042B:2015